



**Notes**

1. All dimensions are in millimeters unless otherwise stated. The contractor to confirm measurements before work is commenced. Any discrepancy to be reported to the Architect.
2. Provide permanent ventilation above all doors and windows except bathroom and toilet doors.
3. Provide damp proof course (dpc) bituminous felt to all walls at ground floor slab level.
4. All drainage pipes passing under buildings and driveways to be encased in 150mm conc. surround.
5. Sanitary works to MoH and local authority's regulations and requirements.
6. Mechanical and electrical works to be done by qualified and registered personnel. Any conflict relating to their layout to be discussed before work is commenced.
7. Electrical work to KPLCo. regulations.
8. DPM to be 1000 gauge polythene sheet.
9. All dimensions to be read from the drawing unless advised otherwise.
10. 600x200mm thick concrete beam to be incorporated so as to provide concrete surround for the 150mm diameter heavy duty p.v.c. carrying the soil water to the conservancy.

Project  
**THE PROPOSED TWO BEDROOMED STAFF HOUSES AT WAJIR**

Client  
**KCAA**

client's sign.....

Architect

Drg title  
**PLANS , SECTION & ELEVATIONS**

designed	G.M.M	drawn	G.M.M
checked	O.D	approved	
date	SEPT'- 2018	date	
scale	1:75 1:100		